

# **IRRIGATION WELL SETBACK CHECKLIST**

DISCLAIMER: This checklist is intended for guidance only. Please consult the applicable rules of Northwest Florida Water Management District (NFWFMD) and any other regulatory authorities. This checklist is a compilation of the requirements of various Rules and Regulations that apply in the NFWFMD and does not supersede any rule requirements. Use of this checklist does not guarantee compliance with all applicable rules or more stringent local ordinances and does not ameliorate the users responsibility to comply with such. This checklist reflects the Rules and Regulations applicable in the NFWFMD at the time the checklist was developed (01/01/2007).

## **Landscape and Recreational Irrigation**

Seventy five feet (75') from onsite sewage treatment and disposal system (OSTDS\*) per 40A-3.504, F.A.C.  
Located in delineated areas as found in Section 62.524.430

Seventy five feet (75') from any of the following Sanitary Hazards as paraphrased below using 62.532 Table 1, Part D as the definition.

Drainage Wells  
Pest/Herb Areas, ie; Golf Courses, Nurseries, Crop Production  
Animal Feeding Operations  
Improperly Abandoned Wells  
Active or Abandoned Phosphate Mines  
Chemical Pipelines  
Railroad Yards  
Domestic Wastewater\*\*  
Cemeteries  
Stormwater Retention/Detention Basins  
Tanks/Lagoons for T/S/D of Liquids  
Cattle Dipping Vats  
Tomato or Egg Wash Areas  
Waste Transfer Areas  
Industrial Waste Storage, Disposal, or Land Application

## **Other Irrigation Wells**

Fifty feet (50') from onsite sewage treatment and disposal system (OSTDS\*) per Table 1 in Chapter 62-532, F.A.C.

\* OSTDS includes septic tanks, other storage tanks, associated drain lines, lift stations and grinder pumps. Solid piping from building to septic tank or from septic tank to drain field is not part of OSTDS.

\*\* Includes sewer transmission lines, reclaimed water lines, bio solids application areas, spray fields, and rapid infiltration basins (RIBS). Lift stations are considered part of OSTDS or domestic wastewater transmission systems.