

DOMESTIC WELL SETBACK CHECKLIST

DISCLAIMER: This checklist is intended for guidance only. Please consult the applicable rules of Northwest Florida Water Management District (NFWFMD) and any other regulatory authorities. This checklist is a compilation of the requirements of various Rules and Regulations that apply in the NFWFMD and does not supersede any rule requirements. Use of this checklist does not guarantee compliance with all applicable rules or more stringent local ordinances and does not ameliorate the users responsibility to comply with such. This checklist reflects the Rules and Regulations applicable in the NFWFMD at the time the checklist was developed (01/01/2007).

- ☐ Seventy five feet (75') from onsite sewage disposal system (OSDS) per 64E-8.003
- ☐ Twenty five feet (25') from building foundations treated with pesticides per 64E-8.002

Other setbacks per 62.532 Table 1, Part C

For Reclaimed Water & Land Application per 62-610

- ☐ 500' from slow rate land application
- ☐ 500' from restricted public access
- ☐ 500' from rapid rate land application
- ☐ 100' from overland flow systems
- ☐ 75' from public access, residential irrigation, edible crop slow-rate land application

For Domestic Wastewater Residuals per 62-640

- ☐ 300' from land application areas

For Petroleum Storage Systems per 62-761

- ☐ 100' from above or below ground storage systems

For Solid Waste Management or Disposal Facilities per 62-701

- ☐ 500' from Disposal Facility
- ☐ 100' from yard trash disposal
- ☐ 100' from storage/treatment of solid waste in tanks

For Feedlot and Dairy Wastewater per 62-670

- ☐ 300' from unlined storage and treatment, or high intensity areas
- ☐ 200' dairy farm waste-land application

75 Feet for Sanitary Hazards per 62.532 Table 1, Part D as the definition

- ☐ Drainage Wells
- ☐ Pest/Herb Areas, ie; Golf Courses, Nurseries, Crop Production
- ☐ Animal Feeding Operations
- ☐ Improperly Abandoned Wells
- ☐ Active or Abandoned Phosphate Mines
- ☐ Chemical Pipelines
- ☐ Railroad Yards
- ☐ Domestic Wastewater*
- ☐ Cemeteries
- ☐ Stormwater Retention/Detention Basins
- ☐ Tanks/Lagoons for T/S/D of Liquids
- ☐ Cattle Dipping Vats
- ☐ Tomato or Egg Wash Areas
- ☐ Waste Transfer Areas **

* Any portion of an OSDS except piping from house to the tank. A "Grinder Pump" is considered an OSDS and therefore the setback does apply to Grinder Pump systems. The transmission line is considered a sanitary hazard.

** Lift stations are considered waste transfer areas and are subject to the setback.