IRRIGATION WELL SETBACK CHECKLIST

DISCLAIMER: This checklist is intended for guidance only. Please consult the applicable rules of Northwest Florida Water Management District (NWFWMD) and any other regulatory authorities. This checklist is a compilation of the requirements of various Rules and Regulations that apply in the NWFWMD and does not supersede any rule requirements. Use of this checklist does not guarantee compliance with all applicable rules or more stringent local ordinances and does not ameliorate the users responsibility to comply with such. This checklist reflects the Rules and Regulations applicable in the NWFWMD at the time the checklist was developed (01/01/2007).

Landscape and Recreational Irrigation

- ☐ Seventy five feet (75') from onsite sewage treatment and disposal system (OSTDS*) per 40A-3.504, F.A.C.
- ☐ Located in delineated areas as found in Section 62.524.430

Seventy five feet (75') from any of the following Sanitary Hazards as paraphrased below using 62.532 Table 1, Part D as the definition.

- ☐ Drainage Wells
- ☐ Pest/Herb Areas, ie; Golf Courses, Nurseries, Crop Production
- ☐ Animal Feeding Operations
- ☐ Improperly Abandoned Wells
- ☐ Active or Abandoned Phosphate Mines
- ☐ Chemical Pipelines
- ☐ Railroad Yards
- ☐ Domestic Wastewater**
- ☐ Cemeteries
- ☐ Stormwater Retention/Detention Basins
- ☐ Tanks/Lagoons for T/S/D of Liquids
- ☐ Cattle Dipping Vats
- ☐ Tomato or Egg Wash Areas
- ☐ Waste Transfer Areas

Other Irrigation Wells

- ☐ Fifty feet (50') from onsite sewage treatment and disposal system (OSTDS*) per Table 1 in Chapter 62-532, F.A.C.

* OTSDS includes septic tank and associated drainlines and lift stations. Grinder pumps and solid piping from building to septic tank or from septic tank to drainfield is not part of OSTDS

** Lift stations are considered part of OSTDS or domestic wastewater transmission systems.