

DEP PUBLIC WATER SYSTEM WELL SETBACK CHECKLIST

Check Box if Well DOES NOT Meet Setback

Has DOH been notified to determine classification of well? If not, why?_____

- Two hundred feet (200') from OSTDS* sanitary hazard per 40A-3.504
- Located in delineated areas as found in Section 62.524.430

Other setbacks per 62.532 Table 1, Part A

For Reclaimed Water & Land Application (62-610)

- 500' from restricted public access, slow rate land application
- 500' from rapid rate land application
- 500' from overland flow systems
- 100' from transmission facilities conveying reclaimed water to restricted public access slow-rate land application systems, rapid rated land application systems, or overland flow systems
- 75' from public access, residential irrigation, or edible crop slow-rate land application systems
- 75' from transmission facilities conveying reclaimed water to public access, residential irrigation, or edible crop slow-rate land application systems

For Domestic Wastewater Residuals (62-640)

- 500' from land application areas

For Phosphogypsum Management (62-673)

- 500' from phosphogypsum stack systems (applies to only shallow, water table wells)

For Petroleum Storage Systems (62-761)

- 100' from above or below ground storage systems

For Solid Waste Management or Disposal Facilities (62-701)

- 500' from Disposal Facility
- 100' from storage/treatment of solid waste in tanks

For Feedlot and Dairy Wastewater (62-670)

- 300' from unlined storage and treatment, or high intensity areas
- 200' dairy farm waste-land application

100 Feet for Sanitary Hazards per 62-555.312, 40A-3.504

- | | | |
|--|--------------------------|---|
| <input type="checkbox"/> Active or Abandoned Mines | <input type="checkbox"/> | <input type="checkbox"/> Domestic waste impoundments/tanks |
| <input type="checkbox"/> Plane or Train Fueling and Maintenance areas | <input type="checkbox"/> | <input type="checkbox"/> Concentrated Aquatic Animal Production |
| <input type="checkbox"/> Drainage/Injection Wells | <input type="checkbox"/> | <input type="checkbox"/> Oil and Gas Production Wells |
| <input type="checkbox"/> Pest/Herb Areas, ie; Golf Courses, Nurseries, Crop Production | | |
| <input type="checkbox"/> Animal Feeding Operations | <input type="checkbox"/> | <input type="checkbox"/> Improperly Constructed Wells |
| <input type="checkbox"/> Improperly Abandoned Wells | <input type="checkbox"/> | <input type="checkbox"/> Chemical Pipelines |
| <input type="checkbox"/> Active or Abandoned Phosphate Mines | <input type="checkbox"/> | <input type="checkbox"/> Railroad Yards |
| <input type="checkbox"/> Domestic Wastewater collection/transmission** | <input type="checkbox"/> | <input type="checkbox"/> Cemeteries/Grave Yards |
| <input type="checkbox"/> Industrial Fluids/Waste impoundments/tanks | <input type="checkbox"/> | <input type="checkbox"/> Stormwater Retention/Detention Basins |
| <input type="checkbox"/> Cattle Dipping Vats | <input type="checkbox"/> | <input type="checkbox"/> Tanks/Lagoons for T/S/D of Liquids |
| <input type="checkbox"/> Tomato or Egg Wash Areas | <input type="checkbox"/> | <input type="checkbox"/> Waste Transfer Areas** |
| <input type="checkbox"/> Junk/Salvage/Scrap Yards | <input type="checkbox"/> | <input type="checkbox"/> Pastures w/ 5 or more grazing animals per acre |
| <input type="checkbox"/> Underground/Aboveground Storage Tanks | <input type="checkbox"/> | <input type="checkbox"/> Railroad Tracks |

If well does not meet setbacks, can well be repositioned to meet setbacks? If not, why?_____

Proposed Well Location: Latitude_____Longitude_____

* OSTDS includes septic tank and associated drainlines, lift stations, and grinder pumps. Solid piping from building to septic tank or from septic tank to drainfield is not part of OSTDS

** Lift stations are considered part of OSTDS or domestic waste water transmission system.